

November 9, 2016

TO: All Bidders

RE: Informal Bid 2017-03 Addendum # 4

#### **ADDENDUM NO. 4**

This **ADDENDUM #4** forms part of Moore County's Informal Bid for the WPCP Gravity Sewer Main and Flume Upgrade for the County of Moore Public Works Department. All requirements of the original specifications remain in effect in their respective order. **Receipt of this Addendum must be acknowledged by its inclusion with the Informal Bid and noted as an inclusion on the sealed envelope.**

**The following changes and/or clarifications are hereby made to the original Informal Bid:**

**The Pump Station Electrical Plan is provided with Addendum # 4.**

**Questions will be accepted until 10:00 am Friday November 11, 2016. A final Addendum will be posted on Monday November 14, 2016.**

**Sealed Bids will be due by 4:00 pm Friday November 18, 2016.**

1. Question: Please provide information on the existing control box. What is the depth, bottom and top elevations, width and length at the top, wall thickness, etc?  
Answer: Please refer to Addendum # 2 documents – can be seen at [www.moorecountync.gov](http://www.moorecountync.gov) Bid Opportunities.
2. Question: What are the bottom elevations of the 18" PVC suction and discharge pipe in the control box?  
Answer: Please refer to Addendum # 2 documents.
3. Question: Is the contractor to fill in dirt behind the block wall? If so how much fill is required?  
Answer: Please refer to Addendum # 2 documents.
4. Question: Both bypass pumping operations plan describe have flow discharging into the influent control box. Is this the same control box that is shown to have new 18" PVC suction and discharge piping? If so please provide a bypass plan to do the work in the control box.  
Answer: Please refer to Addendum # 2 documents.
5. Question: What scope is required for the existing line from Exist MH 1 to MH 10 to MH 11. Is this to be abandoned in place?  
Answer: The contractor will need to do is to plug the existing outlet sewer main at MH #1 and the existing inlet sewer main at MH #11 while the manholes are exposed for installing the new sewer main, grout the holes in MH #1 and MH #11 once the new sewer mains are installed and regROUT the bench for the new flow direction. Moore County will abandon the existing sewer mains and MH #10 at a later date.

**END OF ADDENDUM NO. 4**

Terra Vuncannon  
Purchasing Manager  
County of Moore